



**DEPARTMENT OF PUBLIC HEALTH AND PREVENTIVE MEDICINE
CHIEF WATER ANALYST'S LABORATORY, COIMBATORE - 18.**

From

Thiru.G.Subramanian,M.Sc.,M.Ed.,B.L
Chief Water Analyst,
219, Race Course Road,
Coimbatore 641 018.
Ph.No: 0422-2221542,
E.mail: cwadph.cbe@gmail.com.

To

Sri Chaitanya Techno School,
SF.No.185/1 Marudhamalai
Road, Opp.to Bharath Petrol
Bunk, Vadavalli,
Coimbatore – 641 041.

R.No. 1084/ A3 / 2025, CWA/CBE, M.153

Sir,

Dated: 24.06.2026

Sub: Report on Examination of water sample from Sri Chaitanya
Techno School, SF.No.185/1 Marudhamalai Road, Opp.to
Bharath Petrol Bunk, Vadavalli,Coimbatore.
Collected on 16.06.2026.

A sample of water (Source: Packaged R.O Drinking water from Global Creators, 74-75, Nehru Street, B.R.Puram, Peelamedu, Coimbatore - 641 004. Batch No.08, Mfr.Date : 13.06.2026, Exp Date : 10.07.2027) stated to have been collected on 16.06.2026 from the Purifier Outlet tap at Front office (Ground Floor), Sri Chaitanya Techno School, SF No. 185/1, Maruthamalai Road, Opp: Bharath Petrol Bunk, Coimbatore by Thiru. R. Vignesh Kannan, Administrative Officer was received at this laboratory on the same day from the above addressee to assess its suitability for drinking purpose.

The results of analysis are furnished overleaf.

The sample of water is Colourless and clear in physical appearance.

It is of satisfactory bacteriological quality for drinking.

Judged by the results of analysis, it is of satisfactory Chemical and bacteriological quality for drinking purpose.

However, the total hardness content should be maintained at 30 mg/l, as the Calcium and Magnesium content are very essential minerals for healthy living of human beings.

However, this report is pertinent to this batch only. It should not be used for other batch.

For SREE MURAGAN EDUCATIONAL TRUST

CHIEF WATER ANALYST
COIMBATORE-18.

Copy to Lab / File

Authorised Signatory

DEPARTMENT OF PUBLIC HEALTH AND PREVENTIVE MEDICINE			
CHIEF WATER ANALYST'S LABORATORY, COIMBATORE - 641018			
RESULTS OF EXAMINATION OF SAMPLES OF WATER			
Samples From	Sri Chaitanya Techno School, SF.No.185/1 Marudhamalai Road, Opp.to Bharath Petrol Bunk, Vadavalli,Coimbatore		
Collected by	Thiru.R.Vignesh Kannan, Administrative Officer		
Date of Collection :	16.06.2026		
Date of Receipt :	16.06.2026		
	M.253		
Source as per Label	Purifier Outlet tap at Front office (Ground Floor), Sri Chaitanya Techno School, SF No. 185/1, Maruthamalai Road, Opp: Bharath Petrol Bunk, Coimbatore		
Source	Packaged R.O Drinking water from Global Creators, 74-75, Nehru Street, B.R.Puram, Peelamedu, Coimbatore - 641 004. Batch No.08, Mfr.Date : 13.06.2026, Exp Date : 10.07.2027		
Bacteriological Examination			
Plate count per ml on agar at 37°C - 24 hrs	10		
MPN of Coliform bacteria/100 ml	0		
Nature of Coliform bacteria isolated			
Results of Vibrio test			
Physical Examination			
Colour	Colourless		
Turbidity	1		
Smell	None		
Chemical Examination (in mg/l)			
Total solids	70		
Carbonate Hardness (as CaCo3)	10		
Non-carbonate Hardness (asCaCo3)	10		
Total Hardness	20		
Calcium Hardness (as CaCo3)	12		
Magnesium Hardness (as CaCo3)	8		
Chloride (as Cl)	13		
Ammonia cal Nitrogen (as N)	0		
Albuminiod Nitrogen (as N)			
Oxygen absorbed (Tidy tests) in 4 hrs	0.08		
Nitrate nitrogen as N	0.5		
Acidity / Alkanlinity } Phenolphthalein	0		
as CaCo3 } as Methyl Orange	10		
Fluoride (as F)	0		
pH value	6.5		
Total Iron (as Fe)	0		
Manganese (as Mn)	0		
Qualitative Tests			
Nitrite Nitrogen	Trace		
Sulphate	Trace		
Phosphate	Trace		
Toxic Substance	-		
Electrical conductivity(Reciprocal megohms per cm at 20°C)	100		
Microscopical Examination	Amorphous Matter		

25/6/26
 CHIEF WATER ANALYST
 COIMBATORE-18.

For SREE MURAGAN EDUCATIONAL TRUST

Authorised Laboratory